TAMILNADU FIRE AND RESCUE SERVICE

SCHOOL NO OBJECTION CERTIFICATE

R.C.NØ: 754/V/SPR/2024

Certificated that the M/s.JAIN PUBLIC SCHOOL, at S.No. 260, 261/1, Royal Castle Campus, Thirumudivakkam, Chennai-44, Kundrathur Taluk, Kanchipuram District. comprised of Ground Floor and 2 Upper floors occupied by M/s.JAIN PUBLIC SCHOOL, have Fire Service Rules, and verified by the officers concerned of Fire Service on 10/06/2024 in the presence of PRINCIPAL, M/s.JAIN PUBLIC SCHOOL, S.No. 260, 261/1, Royal Castle Campus, Thirumudivakkam, Chennai-44 and that the building/premises is for Occupancy class School Premises with effect from 10/06/2024 for a period of 09/06/2025 years in accordance with rule and subject to compliance of the conditions.

CONDITIONS

- 1. This License is valid for One year from the date of issue.
- 2. Fire Safety Systems should be maintained in good working condition.
- 3. Mock drill to be conducted periodically with the help of local fire brigade.
- 4. Any erection of permanent or temporary structure should be intimated to this department.
- 5. Further to limit the occupant load and to ensure better fire and life safety measures the Following additional measures are insisted.
- a). Building occupancy capacity should not be more than 4 people per Sq. meter as per The National Building Code-2016.
 - b). The staircase treads and flooring shall be treated with rough finish (Grooving) to Avoid falling of children.
 - c). As per Para 6.3 of the BIS Standards IS 14435:1997 as the Classrooms have only One entrance, the capacity of the class room shall have to be limited to 45 students.

TO:

M/s.Jain Public School, S.No. 260, 261/1, Royal Castle Campus, Thirumudivakkam, Chennai-44 Kundrathur Taluk, Kanchipuram District.

நிலைய அலுவலா நிலைய அலுவலா தீயணைப்பு - மீட்புப்பணி நிலையம் திருப்பெரும்புதூர்.

DATED: 10.06.2024

Copy to: District Officer, Kanchipuram District.