

# TAMILNADU FIRE AND RESCUE SERVICE

## SCHOOL NO OBJECTION CERTIFICATE

DATED: 25/11/2021

R.C.NO: 741/V/SPR/2021

Certificated that the M/s. JAIN PUBLIC SCHOOL, at S.No.260,261/1, Royal Castle Campus, Thirumudivakkam, Chennai-44, Sriperumbudur Taluk, Kanchipuram District Comprised of Ground Floor and 2 Upper floors Occupied by M/s . JAIN PUBLIC SCHOOL, have Fire Service Rules, and verified by the officers concerned of Fire Service on 22/11/2021 in the presence of PRINCIPAL, M/s. JAIN PUBLIC SCHOOL (G+2), S.No.260,261/1, Royal Castle Campus, Thirumudivakkam, Chennai-44, Sriperumbudur Taluk, Kanchipuram District and that the building/premises is for occupancy class School Premises with effect from 25/11/2021 for a period of 24/11/2022 Years in accordance with rule and subject to compliance of the conditions.

## CONDITIONS

1. This License is valid for One year from the date of issue.
2. Fire Safety Systems should be maintained in good working condition.
3. Mock drill to be conducted periodically with the help of local fire brigade.
4. Any erection of permanent or temporary structure should be intimated to this department.
5. Further to limit the occupant load and to ensure better fire and life safety measures the

Following additional measures are insisted.

6. a). Building occupancy capacity should not be more than 4 people per Sq. meter as per The National Building Code-2016.  
b). The staircase treads and flooring shall be treated with rough finish (Grooving) to Avoid falling of children.  
c). As per Para 6.3 of the BIS Standards IS 14435:1997 as the classrooms have only One entrance, the capacity of the class room shall have to be limited to 45 students.

To:

M/s. JAIN PUBLIC SCHOOL,  
S.No.260,261/1, Royal Castle Campus,  
Thirumudivakkam, Chennai-44,  
Sriperumbudur Taluk, Kanchipuram District

*Station Officer.*  
*Fire-Rescue Service*  
*Sriperumbudur 602 111*

Copy to : District officer , Kanchipuram